

This Product MasterSpec Section is licensed by ARCOM to Hunter Panels LLC ("Licensee").

This Product MasterSpec Section modifies the original MasterSpec text and does not include the full content of the original MasterSpec Section.

Revisions made to the original MasterSpec text are made solely by the Licensee and are not endorsed by, or representative of the opinions of, ARCOM or The American Institute of Architects (AIA). Neither AIA nor ARCOM are liable in any way for such revisions or for the use of this Product MasterSpec Section by any end user. A qualified design professional should review and edit the document to suit project requirements.

For more information, contact Hunter Panels LCC, 15 Franklin St., Portland, ME 04101;
Phone: (888) 746-1114 | (207) 761-5678; Fax: (877) 775-1769; Website: www.hunterpanels.com;
Email: HunterTechnical@hpanels.com.

For information about MasterSpec, contact ARCOM at (800) 424-5080 or visit www.MasterSpec.com.

SECTION 072100 - THERMAL INSULATION

TIPS:

To view non-printing **Editor's Notes** that provide guidance for editing, click on MasterWorks/Single-File Formatting/Toggle/Editor's Notes.

To read **detailed research, technical information about products and materials, and coordination checklists**, click on MasterWorks/Supporting Information.

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section Includes:
1. Extruded polystyrene foam-plastic board.
 2. Molded polystyrene foam-plastic board.
 3. Polyisocyanurate foam-plastic board.
 4. Glass-fiber blanket.
 5. Glass-fiber board.
 6. Mineral-wool blanket.
 7. Mineral-wool board.
 8. Loose-fill insulation.
 9. Spray-applied cellulosic insulation.

10. Cellular glass.
11. Reflective insulations.

B. Related Requirements:

1. Section 042000 "Unit Masonry" for insulation installed in masonry cells.
2. Section 061600 "Sheathing" for foam-plastic board sheathing installed directly over wood or steel framing.
3. **[Section 071326 "Self-Adhering Sheet Waterproofing"] [Section 071353 "Elastomeric Sheet Waterproofing"] [Section 071354 "Thermoplastic Sheet Waterproofing"] [Section 071413 "Hot Fluid-Applied Rubberized Asphalt Waterproofing"] [Section 071416 "Cold Fluid-Applied Waterproofing"]** for insulated drainage panels installed with plaza deck insulation.
4. Section 072119 "Foamed-in-Place Insulation" for spray-applied polyurethane foam insulation.
5. **[Section 075113 "Built-up Asphalt Roofing"] [Section 075116 "Built-up Coal Tar Roofing"] [Section 075213 "Atactic-Polypropylene (APP) Modified Bituminous Membrane Roofing"] [Section 075216 "Styrene-Butadiene-Styrene (SBS) Modified Bituminous Membrane Roofing"] [Section 075316 "Chlorosulfonate-Polyethylene (CSPE) Roofing"] [Section 075323 "Ethylene-Propylene-Diene-Monomer (EPDM) Roofing"] [Section 075416 "Ketone Ethylene Ester (KEE) Roofing"] [Section 075419 "Polyvinyl-Chloride (PVC) Roofing"] [Section 075423 "Thermoplastic-Polyolefin (TPO) Roofing"] [Section 075552.13 "Atactic-Polypropylene (APP) Modified Bituminous Protected Membrane Roofing"] [Section 075552.16 "Styrene-Butadiene-Styrene (SBS) Modified Bituminous Protected Membrane Roofing"] [Section 075556 "Fluid-Applied Protected Membrane Roofing"] [and] [Section 075700 "Coated Foamed Roofing"]** for insulation specified as part of roofing construction.
6. **[Section 092300 "Gypsum Plastering"] [Section 092400 "Portland Cement Plastering"] [Section 092613 "Gypsum Veneer Plastering"] [Section 092900 "Gypsum Board"]** for sound attenuation blanket used as acoustic insulation.

1.3 ACTION SUBMITTALS

A. Product Data: For each type of product.

B. Sustainable Design Submittals:

1. Product Data: For recycled content, indicating postconsumer and preconsumer recycled content and cost.
2. Product Data: For adhesives, indicating VOC content.
3. Laboratory Test Reports: For adhesives, indicating compliance with requirements for low-emitting materials.
4. Laboratory Test Reports: For insulation, indicating compliance with requirements for low-emitting materials.

1.4 INFORMATIONAL SUBMITTALS

A. Product Test Reports: For each product, for tests performed by a qualified testing agency.

- B. Evaluation Reports: For foam-plastic insulation, from ICC-ES.

1.5 DELIVERY, STORAGE, AND HANDLING

- A. Protect insulation materials from physical damage and from deterioration due to moisture, soiling, and other sources. Store inside and in a dry location. Comply with manufacturer's written instructions for handling, storing, and protecting during installation.
- B. Protect foam-plastic board insulation as follows:
 - 1. Do not expose to sunlight except to necessary extent for period of installation and concealment.
 - 2. Protect against ignition at all times. Do not deliver foam-plastic board materials to Project site until just before installation time.
 - 3. Quickly complete installation and concealment of foam-plastic board insulation in each area of construction.

PART 2 - PRODUCTS

2.1 EXTRUDED POLYSTYRENE FOAM-PLASTIC BOARD

- A. Extruded polystyrene boards in this article are also called "XPS boards." Roman numeral designators in ASTM C 578 are assigned in a fixed random sequence, and their numeric order does not reflect increasing strength or other characteristics.
- B. Extruded Polystyrene Board, Type X **<Insert drawing designation>**: ASTM C 578, Type X, **15-psi (104-kPa)** minimum compressive strength; unfaced; maximum flame-spread and smoke-developed indexes of 25 and 450, respectively, per ASTM E 84.
 - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. DiversiFoam Products.
 - b. Dow Chemical Company (The).
 - c. Owens Corning.
 - d. **<Insert manufacturer's name>**.
 - 2. Fire Propagation Characteristics: Passes NFPA 285 testing as part of an approved assembly.
- C. Extruded Polystyrene Board, Type IV **<Insert drawing designation>**: ASTM C 578, Type IV, **25-psi (173-kPa)** minimum compressive strength; unfaced; maximum flame-spread and smoke-developed indexes of 25 and 450, respectively, per ASTM E 84.
 - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. DiversiFoam Products.

- b. Dow Chemical Company (The).
 - c. Owens Corning.
 - d. **<Insert manufacturer's name>**.
2. Fire Propagation Characteristics: Passes NFPA 285 testing as part of an approved assembly.
- D. Extruded Polystyrene Board, Type IV, Drainage Panels **<Insert drawing designation>**: ASTM C 578, Type IV, **25-psi (173-kPa)** minimum compressive strength; unfaced; maximum flame-spread and smoke-developed indexes of 25 and 450, respectively, per ASTM E 84; fabricated with shiplap or channel edges and with one side having grooved drainage channels.
1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. DiversiFoam Products.
 - b. Dow Chemical Company (The).
 - c. Owens Corning.
 - d. **<Insert manufacturer's name>**.
- E. Extruded Polystyrene Board, Type VI **<Insert drawing designation>**: ASTM C 578, Type VI, **40-psi (276-kPa)** minimum compressive strength; maximum flame-spread and smoke-developed indexes of 25 and 450, respectively, per ASTM E 84.
1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. DiversiFoam Products.
 - b. Dow Chemical Company (The).
 - c. Owens Corning.
 - d. Soprema, Inc.
 - e. **<Insert manufacturer's name>**.
- F. Extruded Polystyrene Board, Type VI, Drainage Panels **<Insert drawing designation>**: ASTM C 578, Type VI, **40-psi (276-kPa)** minimum compressive strength; unfaced; maximum flame-spread and smoke-developed indexes of 25 and 450, respectively, per ASTM E 84; fabricated with shiplap or channel edges and with one side having grooved drainage channels.
1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. DiversiFoam Products.
 - b. Dow Chemical Company (The).
 - c. Kingspan Insulation Limited.
 - d. Owens Corning.
 - e. **<Insert manufacturer's name>**.
- G. Extruded Polystyrene Board, Type VII **<Insert drawing designation>**: ASTM C 578, Type VII, **60-psi (414-kPa)** minimum compressive strength; maximum flame-spread and smoke-developed indexes of 25 and 450, respectively, per ASTM E 84.

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. DiversiFoam Products.
 - b. Dow Chemical Company (The).
 - c. Owens Corning.
 - d. **<Insert manufacturer's name>**.

- H. Extruded Polystyrene Board, Type VII, Drainage Panels **<Insert drawing designation>**: ASTM C 578, Type VII, **60-psi (414-kPa)** minimum compressive strength; maximum flame-spread and smoke-developed indexes of 25 and 450, respectively, per ASTM E 84; fabricated with shiplap or channel edges and with one side having grooved drainage channels.
 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. DiversiFoam Products.
 - b. Dow Chemical Company (The).
 - c. Owens Corning.
 - d. **<Insert manufacturer's name>**.

- I. Extruded Polystyrene Board, Type V **<Insert drawing designation>**: ASTM C 578, Type V, **100-psi (690-kPa)** minimum compressive strength; maximum flame-spread and smoke-developed indexes of 25 and 450, respectively, per ASTM E 84.
 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. Dow Chemical Company (The).
 - b. Owens Corning.
 - c. **<Insert manufacturer's name>**.

2.2 MOLDED POLYSTYRENE FOAM-PLASTIC BOARD

- A. Molded Polystyrene Board, Type I **<Insert drawing designation>**: ASTM C 578, Type I, **10-psi (69-kPa)** minimum compressive strength.
 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. ACH Foam Technologies, Inc.
 - b. Atlas EPS; a Division of Atlas Roofing Corporation.
 - c. DiversiFoam Products.
 - d. Insulfoam-a division of Carlisle Construction Materials Inc.
 - e. Plymouth Foam, Inc.
 - f. **<Insert manufacturer's name>**.

- B. Molded Polystyrene Board, Type VIII **<Insert drawing designation>**: ASTM C 578, Type VIII, **13-psi (90-kPa)** minimum compressive strength.

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. ACH Foam Technologies, Inc.
 - b. Atlas EPS; a Division of Atlas Roofing Corporation.
 - c. DiversiFoam Products.
 - d. Plymouth Foam, Inc.
 - e. **<Insert manufacturer's name>**.

- C. Molded Polystyrene Board, Type II **<Insert drawing designation>**: ASTM C 578, Type II, **15-psi (104-kPa)** minimum compressive strength.
 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. ACH Foam Technologies, Inc.
 - b. Atlas EPS; a Division of Atlas Roofing Corporation.
 - c. DiversiFoam Products.
 - d. Insulfoam-a division of Carlisle Construction Materials Inc.
 - e. Plymouth Foam, Inc.
 - f. **<Insert manufacturer's name>**.

- D. Molded Polystyrene Board, Type IX **<Insert drawing designation>**: ASTM C 578, Type IX, **25-psi (173-kPa)** minimum compressive strength.
 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. ACH Foam Technologies, Inc.
 - b. Atlas EPS; a Division of Atlas Roofing Corporation.
 - c. DiversiFoam Products.
 - d. Insulfoam-a division of Carlisle Construction Materials Inc.
 - e. Plymouth Foam, Inc.
 - f. **<Insert manufacturer's name>**.

- E. Molded Polystyrene Board, Type XIV **<Insert drawing designation>**: ASTM C 578, Type XIV, **40-psi (276-kPa)** minimum compressive strength.
 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. ACH Foam Technologies, Inc.
 - b. Atlas EPS; a Division of Atlas Roofing Corporation.
 - c. DiversiFoam Products.
 - d. Insulfoam-a division of Carlisle Construction Materials Inc.
 - e. Plymouth Foam, Inc.
 - f. **<Insert manufacturer's name>**.

- F. Molded Polystyrene Board, Type XV **<Insert drawing designation>**: ASTM C 578, Type XV, **60-psi (414-kPa)** minimum compressive strength.

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. ACH Foam Technologies, Inc.
 - b. Atlas EPS; a Division of Atlas Roofing Corporation.
 - c. Insulfoam-a division of Carlisle Construction Materials Inc.
 - d. Plymouth Foam, Inc.
 - e. **<Insert manufacturer's name>**.

2.3 POLYISOCYANURATE FOAM-PLASTIC BOARD

- A. Polyisocyanurate Roof Board Insulation, Fiber-Mat Faced **<Insert drawing designation>**: ASTM C 1289, Type II, Class 1, [**Grade 2, 20 psi (138 kPa)**] [**Grade 3, 25 psi (172 kPa)**].
 1. Basis-of-Design Product: Subject to compliance with requirements, provide Hunter Panels LLC; H-Shield or comparable product of one of the following:
 - a. Atlas Roofing Corporation.
 - b. Rmax, Inc.
 - c. [**Insert manufacturer**].
 2. Thickness: [**1 inch (25 mm)**] [**1.5 inch (13 mm)**] [**1.8 inch (46 mm)**] [**2.0 inch (51 mm)**] [**2.5 inch (64 mm)**] [**2.6 inch (66 mm)**] [**3.0 inch (76 mm)**] [**3.5 inch (89 mm)**] [**3.8 inch (97 mm)**] [**4.0 inch (102 mm)**] [**4.3 inch (109 mm)**] [**4.5 inch (114 mm)**].
- B. Polyisocyanurate Roof Board Insulation, Coated Glass-Fiber-Mat Faced, **<Insert drawing designation>**: ASTM C 1289, Type II, Class 2, [**Grade 2, 20 psi (138 kPa)**] [**Grade 3, 25 psi (172 kPa)**].
 1. Basis-of-Design Product: Subject to compliance with requirements, provide Hunter Panels LLC; H-Shield CG or comparable product of one of the following:
 - a. Atlas Roofing Corporation.
 - b. Rmax, Inc.
 - c. [**Insert manufacturer**].
 2. Thickness: [**1 inch (25 mm)**] [**1.5 inch (13 mm)**] [**1.8 inch (46 mm)**] [**2.0 inch (51 mm)**] [**2.5 inch (64 mm)**] [**2.6 inch (66 mm)**] [**3.0 inch (76 mm)**] [**3.5 inch (89 mm)**] [**3.8 inch (97 mm)**] [**4.0 inch (102 mm)**] [**4.3 inch (109 mm)**] [**4.5 inch (114 mm)**].
- C. Polyisocyanurate Roof Board Insulation, Double-Coated Glass-Fiber-Mat Faced **<Insert drawing designation>**: ASTM C 1289, Type II, Class 2, [**Grade 2, 20 psi (138 kPa)**] [**Grade 3, 25 psi (172 kPa)**].
 1. Basis-of-Design Product: Subject to compliance with requirements, provide Hunter Panels LLC; H-Shield Premier or comparable product of one of the following:
 - a. Atlas Roofing Corporation.
 - b. Rmax, Inc.
 - c. [**Insert manufacturer**].

2. Thickness: **1 inch (25 mm)**.
- D. High-Density Polyisocyanurate Roof Board Insulation Cover Board, Coated-Glass-Mat Faced <**Insert drawing designation**>: ASTM C 1289, Type II, Class 4, Grade 1.
1. Basis-of-Design Product: Subject to compliance with requirements, provide Hunter Panels LLC; H-Shield HD or comparable product of one of the following:
 - a. Atlas Roofing Corporation.
 - b. Rmax, Inc.
 - c. [**Insert manufacturer**].
 2. Thickness: **0.5 inch (13 mm)**.
- E. Composite High-Density Polyisocyanurate Roof Board Insulation, Glass-Fiber-Mat Faced <**Insert drawing designation**>: ASTM C 1289, Type IV, [**Grade 2, 20 psi (138 kPa)**] [**Grade 3, 25 psi (172 kPa)**].
1. Basis-of-Design Product: Subject to compliance with requirements, provide Hunter Panels LLC; H-Shield HD Composite CG or comparable product of one of the following:
 - a. Atlas Roofing Corporation.
 - b. Rmax, Inc.
 - c. [**Insert manufacturer**].
 2. Thickness: [**1 inch (25 mm)**] [**1.5 inch (38 mm)**] [**1.8 inch (46 mm)**] [**2.0 inch (51 mm)**] [**2.5 inch (64 mm)**] [**2.6 inch (66 mm)**] [**3.0 inch (76 mm)**] [**3.5 inch (89 mm)**] [**3.8 inch (97 mm)**] [**4.0 inch (102 mm)**] [**4.3 inch (109 mm)**] [**4.5 inch (114 mm)**].
- F. Composite Polyisocyanurate Roof Board Insulation, Fiberboard Faced, <**Insert drawing designation**>: ASTM C 1289, Type IV, [**Grade 2, 20 psi (138 kPa)**] [**Grade 3, 25 psi (172 kPa)**] with **0.5-inch- (13-mm-)** thick, high-density wood fiberboard facer on one face and a fiber-reinforced facer on the opposite face.
1. Basis-of-Design Product: Subject to compliance with requirements, provide Hunter Panels LLC; H-Shield WF or comparable product of one of the following:
 - a. Atlas Roofing Corporation.
 - b. Rmax, Inc.
 - c. [**Insert manufacturer**].
 2. Thickness: [**1.5 inch (38 mm)**] [**2.0 inch (51 mm)**] [**2.5 inch (64 mm)**] [**3.0 inch (76 mm)**] [**3.5 inch (89 mm)**].
- G. Polyisocyanurate Board Continuous Wall Insulation, Glass-Mat Faced <**Insert drawing designation**>: ASTM C 1289, Type II, Class 2, [**Grade 2, 20 psi (138 kPa)**] [**Grade 3, 25 psi (172 kPa)**] with coated glass facers on both sides.
1. Basis-of-Design Product: Subject to compliance with requirements, provide Hunter Panels LLC; Xci CG or comparable product of one of the following:

- a. Atlas Roofing Corporation.
 - b. Carlisle Coatings & Waterproofing Inc.
 - c. **[Insert manufacturer]**.
2. Thickness: **[1 inch (25 mm)] [1.5 inch (38 mm)] [2 inch (51 mm)] [2.5 inch (64 mm)] [3.0 inch (76 mm)] [3.5 inch (89 mm)] [4.0 inch (102 mm)]**.
 3. Flame Propagation Test: Materials and construction shall be as tested according to NFPA 285.
- H. Polyisocyanurate Board Continuous Wall Insulation, Foil Faced **<Insert drawing designation>**: ASTM C 1289, Type I, Grade 2 and Grade 3, **[Grade 2, 20 psi (138 kPa)] [Grade 3, 25 psi (172 kPa)]**.
1. Basis-of-Design Product: Subject to compliance with requirements, provide Hunter Panels LLC; Xci Foil or comparable product by one of the following:
 - a. Atlas EPS; a Division of Atlas Roofing Corporation.
 - b. Carlisle Coatings & Waterproofing Inc.
 - c. **[Insert manufacturer]**.
 2. Thickness: **[1 inch (25 mm)] [1.5 inch (38 mm)] [2.0 inch (51 mm)] [2.5 inch (64 mm)] [3.0 inch (76 mm)] [3.5 inch (89 mm)] [4.0 inch (102 mm)]**.
- I. Polyisocyanurate Board Continuous Wall Insulation, Foil Faced **<Insert drawing designation>**: ASTM C 1289, Type I, Class 1, Grade 3, Class A, with flame spread index less than 25 per ASTM E 84.
1. Basis-of-Design Product: Subject to compliance with requirements, provide Hunter Panels LLC; Xci Class A or comparable product by one of the following:
 - a. Atlas EPS; a Division of Atlas Roofing Corporation.
 - b. Carlisle Coatings & Waterproofing Inc.
 - c. **[Insert manufacturer]**.
 2. Thickness: **[1.0 inch (25 mm)] [1.5 inch (38 mm)] [1.6 inch (41 mm)] [2.0 inch (51 mm)] [2.5 inch (64 mm)] [3.0 inch (76 mm)] [3.5 inch (89 mm)] [4.0 inch (102 mm)]**.
 3. Flame Propagation Test: Materials and construction shall be as tested according to NFPA 285.
- J. Polyisocyanurate Board Continuous Wall Insulation, Foil Faced **<Insert drawing designation>**: ASTM C 1289, foil faced, Type I, Class 1, Grade 3, with **15-mil (0.38-mm)** glass-fiber-reinforced foil facers.
1. Basis-of-Design Product: Subject to compliance with requirements, provide Hunter Panels LLC; Xci 286 or a comparable product by one of the following:
 - a. Atlas EPS; a Division of Atlas Roofing Corporation.
 - b. Atlas Roofing Corporation.
 - c. **<Insert manufacturer's name>**.

2. Thickness: [**1 inch (25 mm)**] [**1.5 inch (38 mm)**] [**1.6 inch (41 mm)**] [**2.0 inch (51 mm)**] [**2.5 inch (64 mm)**] [**3.0 inch (76 mm)**] [**3.5 inch (89 mm)**].
3. Fire Propagation Characteristics: Passes NFPA 285 testing as part of an approved assembly.

2.4 GLASS-FIBER BLANKET

- A. Insulation shall comply with the requirements of the California Department of Public Health's "Standard Method for the Testing and Evaluation of Volatile Organic Chemical Emissions from Indoor Sources Using Environmental Chambers."
- B. Recycled Content: Postconsumer recycled content plus one-half of preconsumer recycled content not less than **<Insert value>** percent.
- C. Glass-Fiber Blanket, Unfaced **<Insert drawing designation>**: ASTM C 665, Type I; with maximum flame-spread and smoke-developed indexes of 25 and 50, respectively, per ASTM E 84; passing ASTM E 136 for combustion characteristics.
 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. CertainTeed Corporation.
 - b. Johns Manville; a Berkshire Hathaway company.
 - c. Knauf Insulation.
 - d. Owens Corning.
 - e. **<Insert manufacturer's name>**.
- D. Glass-Fiber Blanket, Polypropylene-Scrim-Kraft Faced **<Insert drawing designation>**: ASTM C 665, Type II (nonreflective faced), Class A (faced surface with a flame-spread index of 25 or less); Category 1 (membrane is a vapor barrier).
 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. CertainTeed Corporation.
 - b. Johns Manville; a Berkshire Hathaway company.
 - c. Knauf Insulation.
 - d. Owens Corning.
 - e. **<Insert manufacturer's name>**.
- E. Glass-Fiber Blanket, Kraft Faced **<Insert drawing designation>**: ASTM C 665, Type II (nonreflective faced), Class C (faced surface not rated for flame propagation); Category 1 (membrane is a vapor barrier).
 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. CertainTeed Corporation.
 - b. Johns Manville; a Berkshire Hathaway company.
 - c. Knauf Insulation.

- d. Owens Corning.
 - e. **<Insert manufacturer's name>**.
- F. Glass-Fiber Blanket, Reinforced-Foil Faced **<Insert drawing designation>**: ASTM C 665, Type III (reflective faced), Class A (faced surface with a flame-spread index of 25 or less); Category 1 (membrane is a vapor barrier), faced with foil scrim, foil-scrim kraft, or foil-scrim polyethylene.
1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. CertainTeed Corporation.
 - b. Johns Manville; a Berkshire Hathaway company.
 - c. Knauf Insulation.
 - d. Owens Corning.
 - e. **<Insert manufacturer's name>**.
- G. Glass-Fiber Blanket, Foil Faced **<Insert drawing designation>**: ASTM C 665, Type III (reflective faced), Class B (faced surface with a flame-propagation resistance of 0.12 W/sq. cm); Category 1 (membrane is a vapor barrier), faced with foil scrim, foil-scrim kraft, or foil-scrim polyethylene.
1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. CertainTeed Corporation.
 - b. Johns Manville; a Berkshire Hathaway company.
 - c. Knauf Insulation.
 - d. Owens Corning.
 - e. **<Insert manufacturer's name>**.

2.5 GLASS-FIBER BOARD

- A. Insulation shall comply with the requirements of the California Department of Public Health's "Standard Method for the Testing and Evaluation of Volatile Organic Chemical Emissions from Indoor Sources Using Environmental Chambers."
- B. Recycled Content: Postconsumer recycled content plus one-half of preconsumer recycled content not less than **<Insert value>** percent.
- C. Glass-Fiber Board, Unfaced **<Insert drawing designation>**: ASTM C 612, Type IA; unfaced, with maximum flame-spread and smoke-developed indexes of 25 and 50, respectively, per ASTM E 84[, **passing ASTM E 136 for combustion characteristics**]. Nominal density of **2.25 lb/cu. ft (36 kg/cu. m)**, thermal resistivity of **4.3 deg F x h x sq. ft./Btu x in. at 75 deg F (29.8 K x m/W at 24 deg C)**.
 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. CertainTeed Corporation.

- b. Johns Manville; a Berkshire Hathaway company.
 - c. Knauf Insulation.
 - d. Owens Corning.
 - e. **<Insert manufacturer's name>**.
- D. Glass-Fiber Board, Faced **<Insert drawing designation>**: ASTM C 612, Type IA; faced on one side with foil-scrim-kraft or foil-scrim-polyethylene vapor retarder, with maximum flame-spread and smoke-developed indexes of 25 and 50, respectively, per ASTM E 84. Nominal density of **2.25 lb/cu. ft. (36 kg/cu. m)**, thermal resistivity of **4.3 deg F x h x sq. ft./Btu x in. at 75 deg F (29.8 K x m/W at 24 deg C)**.
1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. CertainTeed Corporation.
 - b. Johns Manville; a Berkshire Hathaway company.
 - c. Knauf Insulation.
 - d. Owens Corning.
 - e. **<Insert manufacturer's name>**.
- E. Glass-Fiber Board, Unfaced **<Insert drawing designation>**: ASTM C 612, Type IA; unfaced, with maximum flame-spread and smoke-developed indexes of 25 and 50, respectively, per ASTM E 84[, **passing ASTM E 136 for combustion characteristics**]. Nominal density of **3 lb/cu. ft. (48 kg/cu. m)**, thermal resistivity of **4.3 deg F x h x sq. ft./Btu x in. at 75 deg F (29.8 K x m/W at 24 deg C)**.
1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. CertainTeed Corporation.
 - b. Johns Manville; a Berkshire Hathaway company.
 - c. Knauf Insulation.
 - d. Owens Corning.
 - e. **<Insert manufacturer's name>**.
- F. Glass-Fiber Board, Faced **<Insert drawing designation>**: ASTM C 612, Type IA; faced on one side with foil-scrim-kraft or foil-scrim-polyethylene vapor retarder, with maximum flame-spread and smoke-developed indexes of 25 and 50, respectively, per ASTM E 84. Nominal density of **3 lb/cu. ft. (48 kg/cu. m)**, thermal resistivity of **4.3 deg F x h x sq. ft./Btu x in. at 75 deg F (29.8 K x m/W at 24 deg C)**.
1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. CertainTeed Corporation.
 - b. Johns Manville; a Berkshire Hathaway company.
 - c. Knauf Insulation.
 - d. Owens Corning.
 - e. **<Insert manufacturer's name>**.

- G. Glass-Fiber Board, Unfaced <Insert drawing designation>: ASTM C 612, Type IA; unfaced, with maximum flame-spread and smoke-developed indexes of 25 and 50, respectively, per ASTM E 84[, **passing ASTM E 136 for combustion characteristics**]. Nominal density of **4.25 lb/cu. ft. (68 kg/cu. m)**, thermal resistivity of **4.3 deg F x h x sq. ft./Btu x in. at 75 deg F (29.8 K x m/W at 24 deg C)**.
1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. Knauf Insulation.
 - b. <Insert manufacturer's name>.
- H. Glass-Fiber Board, Faced <Insert drawing designation>: ASTM C 612, Type IA; faced on one side with foil-scrim-kraft or foil-scrim-polyethylene vapor retarder, with maximum flame-spread and smoke-developed indexes of 25 and 50, respectively, per ASTM E 84. Nominal density of **4.25 lb/cu. ft. (68 kg/cu. m)**, thermal resistivity of **4.3 deg F x h x sq. ft./Btu x in. at 75 deg F (29.8 K x m/W at 24 deg C)**.
1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. Knauf Insulation.
 - b. <Insert manufacturer's name>.
- I. Glass-Fiber Board, Unfaced <Insert drawing designation>: ASTM C 612, Type IA; unfaced, with maximum flame-spread and smoke-developed indexes of 25 and 50, respectively, per ASTM E 84[, **passing ASTM E 136 for combustion characteristics**]. Nominal density of **6 lb/cu. ft. (96 kg/cu. m)**, thermal resistivity of **4.4 deg F x h x sq. ft./Btu x in. at 75 deg F (30.5 K x m/W at 24 deg C)**.
1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. Johns Manville; a Berkshire Hathaway company.
 - b. Knauf Insulation.
 - c. <Insert manufacturer's name>.
- J. Glass-Fiber Board, Faced <Insert drawing designation>: ASTM C 612, Type IA; faced on one side with foil-scrim-kraft or foil-scrim-polyethylene vapor retarder, with maximum flame-spread and smoke-developed indexes of 25 and 50, respectively, per ASTM E 84. Nominal density of **6 lb/cu. ft. (96 kg/cu. m)**, thermal resistivity of not less than **4.34 deg F x h x sq. ft./Btu x in. at 75 deg F (30.1 K x m/W at 24 deg C)**.
1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. CertainTeed Corporation.
 - b. Johns Manville; a Berkshire Hathaway company.
 - c. Knauf Insulation.
 - d. Owens Corning.
 - e. <Insert manufacturer's name>.

2.6 MINERAL-WOOL BLANKETS

- A. Insulation shall comply with the requirements of the California Department of Public Health's "Standard Method for the Testing and Evaluation of Volatile Organic Chemical Emissions from Indoor Sources Using Environmental Chambers."
- B. Recycled Content: Postconsumer recycled content plus one-half of preconsumer recycled content not less than **<Insert value>** percent.
- C. Mineral-Wool Blanket, Unfaced **<Insert drawing designation>**: ASTM C 665, Type I (blankets without membrane facing); consisting of fibers; with maximum flame-spread and smoke-developed indexes of 25 and 50, respectively, per ASTM E 84; passing ASTM E 136 for combustion characteristics.
 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. Industrial Insulation Group, LLC (IIG-LLC).
 - b. ROXUL.
 - c. Thermafiber, Inc.; an Owens Corning company.
 - d. **<Insert manufacturer's name>**.
- D. Mineral-Wool Blanket, Reinforced-Foil Faced **<Insert drawing designation>**: ASTM C 665, Type III (reflective faced), Class A (faced surface with a flame-spread index of 25 or less per ASTM E 84); Category 1 (membrane is a vapor barrier), faced with foil scrim, foil-scrim kraft, or foil-scrim polyethylene.
 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. Thermafiber, Inc.; an Owens Corning company.
 - b. **<Insert manufacturer's name>**.

2.7 MINERAL-WOOL BOARD

- A. Insulation shall comply with the requirements of the California Department of Public Health's "Standard Method for the Testing and Evaluation of Volatile Organic Chemical Emissions from Indoor Sources Using Environmental Chambers."
- B. Recycled Content: Postconsumer recycled content plus one-half of preconsumer recycled content not less than **<Insert value>** percent.
- C. Mineral-Wool Board, Types IA and IB, Unfaced **<Insert drawing designation>**: ASTM C 612, Types IA and IB; with maximum flame-spread and smoke-developed indexes of 15 and zero, respectively, per ASTM E 84; passing ASTM E 136 for combustion characteristics. Nominal density of **4 lb/cu. ft. (64 kg/cu. m)**.
 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:

- a. Industrial Insulation Group, LLC (IIG-LLC).
 - b. ROXUL.
 - c. Thermafiber, Inc.; an Owens Corning company.
 - d. **<Insert manufacturer's name>**.
- D. Mineral-Wool Board, Types IA and IB, Faced **<Insert drawing designation>**: ASTM C 612, Types IA and IB; faced on one side with foil-scrim or foil-scrim-polyethylene vapor retarder; with maximum flame-spread and smoke-developed indexes of 15 and zero, respectively, per ASTM E 84. Nominal density of **4 lb/cu. ft. (64 kg/cu. m)**.
1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. Industrial Insulation Group, LLC (IIG-LLC).
 - b. Thermafiber, Inc.; an Owens Corning company.
 - c. **<Insert manufacturer's name>**.
- E. Mineral-Wool Board, Type II, Unfaced **<Insert drawing designation>**: ASTM C 612, Type II; with maximum flame-spread and smoke-developed indexes of 15 and zero, respectively, per ASTM E 84; passing ASTM E 136 for combustion characteristics. Nominal density of **6 lb/cu. ft. (96 kg/cu. m)**.
1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. Industrial Insulation Group, LLC (IIG-LLC).
 - b. ROXUL.
 - c. Thermafiber, Inc.; an Owens Corning company.
 - d. **<Insert manufacturer's name>**.
- F. Mineral-Wool Board, Type II, Faced **<Insert drawing designation>**: ASTM C 612, Type II; faced on one side with foil-scrim or foil-scrim-polyethylene vapor retarder; with maximum flame-spread and smoke-developed indexes of 15 and zero, respectively, per ASTM E 84. Nominal density of **6 lb/cu. ft. (96 kg/cu. m)**.
1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. Industrial Insulation Group, LLC (IIG-LLC).
 - b. Thermafiber, Inc.; an Owens Corning company.
 - c. **<Insert manufacturer's name>**.
- G. Mineral-Wool Board, Type III, Unfaced **<Insert drawing designation>**: ASTM C 612, Type III; with maximum flame-spread and smoke-developed indexes of 15 and zero, respectively, per ASTM E 84; passing ASTM E 136 for combustion characteristics. Nominal density of **8 lb/cu. ft. (128 kg/cu. m)**.
1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. Industrial Insulation Group, LLC (IIG-LLC).

- b. ROXUL.
 - c. Thermafiber, Inc.; an Owens Corning company.
 - d. **<Insert manufacturer's name>**.
- H. Mineral-Wool Board, Type III, Faced **<Insert drawing designation>**: ASTM C 612, Type III; faced on one side with foil-scrim or foil-scrim-polyethylene vapor retarder; with maximum flame-spread and smoke-developed indexes of 15 and zero, respectively, per ASTM E 84. Nominal density of **8 lb/cu. ft. (128 kg/cu. m)**.
1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. Industrial Insulation Group, LLC (IIG-LLC).
 - b. ROXUL.
 - c. Thermafiber, Inc.; an Owens Corning company.
 - d. **<Insert manufacturer's name>**.

2.8 LOOSE-FILL INSULATION

- A. Insulation shall comply with the requirements of the California Department of Public Health's "Standard Method for the Testing and Evaluation of Volatile Organic Chemical Emissions from Indoor Sources Using Environmental Chambers."
- B. Recycled Content: Postconsumer recycled content plus one-half of preconsumer recycled content not less than **<Insert value>** percent.
- C. Cellulosic-Fiber Loose-Fill Insulation **<Insert drawing designation>**: ASTM C 739, chemically treated for flame-resistance, processing, and handling characteristics.
1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. Central Fiber LLC.
 - b. GreenFiber.
 - c. Hamilton Manufacturing Inc.
 - d. Nu-Wool Co., Inc.
 - e. **<Insert manufacturer's name>**.
- D. Glass-Fiber Loose-Fill Insulation **<Insert drawing designation>**: ASTM C 764, [**Type I for pneumatic application**] [**or**] [**Type II for poured application**]; with maximum flame-spread and smoke-developed indexes of 5, per ASTM E 84.
1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. CertainTeed Corporation.
 - b. Johns Manville; a Berkshire Hathaway company.
 - c. Knauf Insulation.
 - d. **<Insert manufacturer's name>**.

2.9 SPRAY-APPLIED CELLULOSIC INSULATION

- A. Insulation shall comply with the requirements of the California Department of Public Health's "Standard Method for the Testing and Evaluation of Volatile Organic Chemical Emissions from Indoor Sources Using Environmental Chambers."
- B. Recycled Content: Postconsumer recycled content plus one-half of preconsumer recycled content not less than **<Insert value>** percent.
- C. Self-Supported, Spray-Applied Cellulosic Insulation **<Insert drawing designation>**: ASTM C 1149, [**Type I (materials applied with liquid adhesive; suitable for either exposed or enclosed applications),**] [**Type II (materials containing a dry adhesive activated by water during installation; intended only for enclosed or covered applications),**] [**Type III (materials containing an adhesive mixed with water during application; intended for application on attic floors),**] chemically treated for flame-resistance, processing, and handling characteristics.
 - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. Central Fiber LLC.
 - b. GreenFiber.
 - c. Hamilton Manufacturing Inc.
 - d. International Cellulose Corp.
 - e. Nu-Wool Co., Inc.
 - f. **<Insert manufacturer's name>**.

2.10 CELLULAR GLASS

- A. Cellular Glass **<Insert drawing designation>**: ASTM C 552, [**Type I (flat block)**] [**Type IV (board)**] [**faced on both sides with manufacturer's special kraft-paper sheets laminated to glass block with asphalt**].
 - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. Pittsburgh Corning Corporation.
 - b. **<Insert manufacturer's name>**.

2.11 REFLECTIVE INSULATIONS

- A. Insulation shall comply with the requirements of the California Department of Public Health's "Standard Method for the Testing and Evaluation of Volatile Organic Chemical Emissions from Indoor Sources Using Environmental Chambers."
- B. Reflective Insulation: ASTM C 1224, with one or more low-emittance surfaces with emittance value of 0.1 or less as measured per ASTM C 1371.

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. Covertch Fabricating Inc.
 - b. Fi-Foil Company.
 - c. Innovative Energy, Inc.
 - d. Innovative Insulation, Inc.
 - e. Insulation Solutions, Inc.
 - f. Reflectix Inc.
 - g. TVM Building Products.
 - h. **<Insert manufacturer's name>**.
 2. Construction: [**Surfaces separated with internal expanders**] [**Surfaces separated by single-layer polyethylene bubble film**] [**Surfaces separated by double-layer polyethylene bubble film**] **<Insert construction>**.
 3. Surface-Burning Characteristics: Maximum flame-spread and smoke-developed indexes of [**25 and 50**] [**25 and 450**] **<Insert values>**, respectively.
 4. Water-Vapor Transmission: [**1 perm, maximum**] [**5 perms or greater**].
- C. Sheet Radiant Barrier: ASTM C 1313/C 1313M with at least one surface with emittance value of 0.1 or less as measured per ASTM C 1371.
1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. Covertch Fabricating Inc.
 - b. Fi-Foil Company.
 - c. Innovative Energy, Inc.
 - d. Innovative Insulation, Inc.
 - e. Insulation Solutions, Inc.
 - f. Reflectix Inc.
 - g. TVM Building Products.
 - h. **<Insert manufacturer's name>**.
 2. Construction: [**Foil on one side of substrate**] [**Foil on both sides of substrate**] [**Vacuum metallizing on substrate**].
 3. Surface-Burning Characteristics: Maximum flame-spread and smoke-developed indexes of [**5 and 10**] **<Insert values>**, respectively.
 4. Tear Resistance: **<Insert value>**.
 5. Water-Vapor Transmission: [**1 perm, maximum**] [**5 perms or greater**].
 6. Sheet Width: **<Insert width>**.
- D. Interior Radiation Control Coating System: Silver-colored, low-emissivity, [**solvent**] [**water**]-based coating; with a surface emittance value of 0.25 or less as measured per ASTM C 1371.
1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. SOLEC Corporation.
 - b. STS Coatings, Inc.
 - c. **<Insert manufacturer's name>**.

2.12 INSULATION FASTENERS

- A. Adhesively Attached, Spindle-Type Anchors: Plate welded to projecting spindle; capable of holding insulation of specified thickness securely in position with self-locking washer in place.
1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. AGM Industries, Inc.
 - b. Gemco.
 - c. **<Insert manufacturer's name>**.
 2. Plate: Perforated, galvanized carbon-steel sheet, **0.030-inch (0.762-mm)** thick by **2 inches (50 mm)** square.
 3. Spindle: Copper-coated, low-carbon steel; fully annealed; **0.105 inch (2.67 mm)** in diameter; length to suit depth of insulation.
- B. Adhesively Attached, Angle-Shaped, Spindle-Type Anchors: Angle welded to projecting spindle; capable of holding insulation of specified thickness securely in position with self-locking washer in place.
1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. Gemco.
 - b. **<Insert manufacturer's name>**.
 2. Angle: Formed from **0.030-inch (0.762-mm)** thick, perforated, galvanized carbon-steel sheet with each leg **2 inches (50 mm)** square.
 3. Spindle: Copper-coated, low-carbon steel; fully annealed; **0.105 inch (2.67 mm)** in diameter; length to suit depth of insulation.
- C. Insulation-Retaining Washers: Self-locking washers formed from **0.016-inch- (0.41-mm-)** thick, galvanized-steel sheet, with beveled edge for increased stiffness, sized as required to hold insulation securely in place, but not less than **1-1/2 inches (38 mm)** square or in diameter.
1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. AGM Industries, Inc.
 - b. Gemco.
 - c. **<Insert manufacturer's name>**.
 2. Protect ends with capped self-locking washers incorporating a spring steel insert to ensure permanent retention of cap in the following locations:
 - a. Crawl spaces.
 - b. Ceiling plenums.
 - c. Attic spaces.
 - d. **<Insert location>**.

- D. Insulation Standoff: Spacer fabricated from galvanized mild-steel sheet for fitting over spindle of insulation anchor to maintain air space of [1 inch (25 mm)] [2 inches (50 mm)] [3 inches (76 mm)] between face of insulation and substrate to which anchor is attached.
1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. Gemco.
 - b. <Insert manufacturer's name>.
- E. Anchor Adhesive: Product with demonstrated capability to bond insulation anchors securely to substrates without damaging insulation, fasteners, or substrates.
1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. AGM Industries, Inc.
 - b. Gemco.
 - c. <Insert manufacturer's name>.

2.13 ACCESSORIES

- A. Insulation for Miscellaneous Voids:
1. Glass-Fiber Insulation: ASTM C 764, Type II, loose fill; with maximum flame-spread and smoke-developed indexes of 5, per ASTM E 84.
 2. Spray Polyurethane Foam Insulation: ASTM C 1029, Type II, closed cell, with maximum flame-spread and smoke-developed indexes of 75 and 450, respectively, per ASTM E 84.
- B. Adhesive for Bonding Insulation: Product compatible with insulation and air and water barrier materials, and with demonstrated capability to bond insulation securely to substrates without damaging insulation and substrates.
1. Adhesives shall have a VOC content of [70] <Insert value> g/L or less.
 2. Adhesive shall comply with the testing and product requirements of the California Department of Public Health's "Standard Method for the Testing and Evaluation of Volatile Organic Chemical Emissions from Indoor Sources Using Environmental Chambers."
- C. Asphalt Coating for Cellular-Glass Block Insulation: Cutback asphalt or asphalt emulsion of type recommended by manufacturer of cellular-glass block insulation.
- D. Eave Ventilation Troughs: Preformed, rigid fiberboard or plastic sheets designed and sized to fit between roof framing members and to provide ventilation between insulated attic spaces and vented eaves.

PART 3 - EXECUTION

3.1 PREPARATION

- A. Clean substrates of substances that are harmful to insulation, including removing projections capable of puncturing insulation or vapor retarders, or that interfere with insulation attachment.

3.2 INSTALLATION, GENERAL

- A. Comply with insulation manufacturer's written instructions applicable to products and applications.
- B. Install insulation that is undamaged, dry, and unsoiled and that has not been left exposed to ice, rain, or snow at any time.
- C. Extend insulation to envelop entire area to be insulated. Fit tightly around obstructions and fill voids with insulation. Remove projections that interfere with placement.
- D. Provide sizes to fit applications and selected from manufacturer's standard thicknesses, widths, and lengths. Apply single layer of insulation units unless multiple layers are otherwise shown or required to make up total thickness or to achieve R-value.

3.3 INSTALLATION OF SLAB INSULATION

- A. On vertical slab edge and foundation surfaces, set insulation units using manufacturer's recommended adhesive according to manufacturer's written instructions.
 - 1. If not otherwise indicated, extend insulation a minimum of [24 inches (610 mm)] [36 inches (915 mm)] <Insert dimension> below exterior grade line.
- B. On horizontal surfaces, loosely lay insulation units according to manufacturer's written instructions. Stagger end joints and tightly abut insulation units.
 - 1. If not otherwise indicated, extend insulation a minimum of [24 inches (610 mm)] [36 inches (915 mm)] <Insert dimension> in from exterior walls.

3.4 INSTALLATION OF FOUNDATION WALL INSULATION

- A. Butt panels together for tight fit.
- B. Anchor Installation: Install board insulation on concrete substrates by adhesively attached, spindle-type insulation anchors as follows:
 - 1. Fasten insulation anchors to concrete substrates with insulation anchor adhesive according to anchor manufacturer's written instructions. Space anchors according to insulation manufacturer's written instructions for insulation type, thickness, and application.

2. Apply insulation standoffs to each spindle to create cavity width indicated on Drawings between concrete substrate and insulation.
 3. After adhesive has dried, install board insulation by pressing insulation into position over spindles and securing it tightly in place with insulation-retaining washers, taking care not to compress insulation.
 4. Where insulation will not be covered by other building materials, apply capped washers to tips of spindles.
- C. Adhesive Installation: Install with adhesive or press into tacky waterproofing or dampproofing according to manufacturer's written instructions.

3.5 INSTALLATION OF CAVITY-WALL INSULATION

- A. Foam-Plastic Board Insulation: Install pads of adhesive spaced approximately **24 inches (610 mm)** o.c. both ways on inside face and as recommended by manufacturer. Fit courses of insulation between wall ties and other obstructions, with edges butted tightly in both directions. Press units firmly against inside substrates.
1. Supplement adhesive attachment of insulation by securing boards with two-piece wall ties designed for this purpose and specified in Section 042000 "Unit Masonry."
- B. Cellular-Glass Board Insulation: Install with closely fitting joints using **[adhesive pad]** **[serrated trowel]** attachment method according to manufacturer's written instructions.

3.6 INSTALLATION OF INSULATION IN FRAMED CONSTRUCTION

- A. Blanket Insulation: Install in cavities formed by framing members according to the following requirements:
1. Use insulation widths and lengths that fill the cavities formed by framing members. If more than one length is required to fill the cavities, provide lengths that will produce a snug fit between ends.
 2. Place insulation in cavities formed by framing members to produce a friction fit between edges of insulation and adjoining framing members.
 3. Maintain **3-inch (76-mm)** clearance of insulation around recessed lighting fixtures not rated for or protected from contact with insulation.
 4. Attics: Install eave ventilation troughs between roof framing members in insulated attic spaces at vented eaves.
 5. For metal-framed wall cavities where cavity heights exceed **96 inches (2438 mm)**, support unfaced blankets mechanically and support faced blankets by taping flanges of insulation to flanges of metal studs.
 6. For wood-framed construction, install blankets according to ASTM C 1320 and as follows:
 - a. With faced blankets having stapling flanges, lap blanket flange over flange of adjacent blanket to maintain continuity of vapor retarder once finish material is installed over it.

7. Vapor-Retarder-Faced Blankets: Tape joints and ruptures in vapor-retarder facings, and seal each continuous area of insulation to ensure airtight installation.
 - a. Exterior Walls: Set units with facing placed toward **[exterior of construction]** **[interior of construction]** **[as indicated on Drawings]**.
 - b. Interior Walls: Set units with facing placed **[as indicated on Drawings]** **[toward areas of high humidity]** **<Insert location>**.
- B. Miscellaneous Voids: Install insulation in miscellaneous voids and cavity spaces where required to prevent gaps in insulation using the following materials:
 1. Glass-Fiber Insulation: Compact to approximately 40 percent of normal maximum volume equaling a density of approximately **2.5 lb/cu. ft. (40 kg/cu. m)**.
 2. Spray Polyurethane Insulation: Apply according to manufacturer's written instructions.
- C. Loose-Fill Insulation: Apply according to ASTM C 1015 and manufacturer's written instructions. Level horizontal applications to uniform thickness as indicated, lightly settle to uniform density, but do not compact excessively.
 1. For cellulosic-fiber loose-fill insulation, comply with CIMA's Bulletin #2, "Standard Practice for Installing Cellulose Insulation."
- D. Spray-Applied Cellulosic Insulation: Apply spray-applied insulation according to manufacturer's written instructions. Do not apply insulation until installation of pipes, ducts, conduits, wiring, and electrical outlets in walls is completed and windows, electrical boxes, and other items not indicated to receive insulation are masked. After insulation is applied, make flush with face of studs by using method recommended by insulation manufacturer.

3.7 INSTALLATION OF CURTAIN-WALL INSULATION

- A. Install board insulation in curtain-wall construction according to curtain-wall manufacturer's written instructions.
 1. Hold insulation in place by securing metal clips and straps or integral pockets within window frames, spaced at intervals recommended in writing by insulation manufacturer to hold insulation securely in place without touching spandrel glass. Maintain cavity width of dimension indicated on Drawings between insulation and glass.
 2. Install insulation to fit snugly without bowing.

3.8 INSTALLATION OF REFLECTIVE INSULATION

- A. Install sheet reflective insulation according to ASTM C 727.
- B. Install sheet radiant barriers according to ASTM C 1744.
- C. Install interior radiation control coating system according to ASTM C 1321.

3.9 PROTECTION

- A. Protect installed insulation from damage due to harmful weather exposures, physical abuse, and other causes. Provide temporary coverings or enclosures where insulation is subject to abuse and cannot be concealed and protected by permanent construction immediately after installation.

END OF SECTION 072100