

**TABLE 502.1.2**

**BUILDING ENVELOPE REQUIREMENTS OPAQUE ELEMENT, MAXIMUM U-FACTORS**

CLIMATE ZONE	1		2		3		4 EXCEPT MARINE		SAND MARINE 4		6		7		8		
	All other	Group R	All other	Group R	All other	Group R	All other	Group R	All other	Group R	All other	Group R	All other	Group R	All other	Group R	
<b>Roofs</b>																	
Insulation entirely above deck	U-0.063	U-0.048	U-0.048	U-0.048	U-0.048	U-0.048	U-0.048	U-0.048	U-0.048	U-0.048	U-0.048	U-0.048	U-0.039	U-0.039	U-0.039	U-0.039	
Metal buildings	U-0.065	U-0.065	U-0.055	U-0.055	U-0.055	U-0.055	U-0.055	U-0.055	U-0.055	U-0.055	U-0.055	U-0.049	U-0.049	U-0.049	U-0.049	U-0.035	U-0.035
Attic and other	U-0.034	U-0.027	U-0.027	U-0.027	U-0.027	U-0.027	U-0.027	U-0.027	U-0.027	U-0.027	U-0.027	U-0.027	U-0.027	U-0.027	U-0.027	U-0.027	U-0.027
<b>Walls, Above Grade</b>																	
Mass	U-0.058	U-0.151	U-0.151	U-0.123	U-0.123	U-0.104	U-0.104	U-0.090	U-0.90	U-0.80	U-0.080	U-0.071	U-0.071	U-0.071	U-0.071	U-0.052	
Metal building	U-0.093	U-0.093	U-0.093	U-0.093	U-0.084	U-0.084	U-0.084	U-0.084	U-0.069	U-0.069	U-0.069	U-0.069	U-0.057	U-0.057	U-0.057	U-0.057	
Metal framed	U-0.124	U-0.124	U-0.124	U-0.064	U-0.084	U-0.064	U-0.064	U-0.064	U-0.064	U-0.064	U-0.064	U-0.064	U-0.057	U-0.064	U-0.052	U-0.064	U-0.037
Wood framed and other	U-0.089	U-0.089	U-0.089	U-0.089	U-0.089	U-0.089	U-0.089	U-0.064	U-0.064	U-0.051	U-0.051	U-0.051	U-0.051	U-0.051	U-0.051	U-0.036	U-0.036
<b>Walls, Below Grade</b>																	
Below-grade walls	C-1.140	C-1.140	C-1.140	C-1.140	C-1.140	C-1.140	C-1.140	C-0.119	C-0.119	C-0.119	C-0.119	C-0.119	C-0.119	C-0.119	C-0.092	C-0.119	C-0.075
<b>Floors</b>																	
Mass	U-0.322	U-0.322	U-0.107	U-0.087	U-0.107	U-0.087	U-0.087	U-0.074	U-0.074	U-0.064	U-0.064	U-0.057	U-0.064	U-0.051	U-0.057	U-0.051	
Joist Framing	U-0.282	U-0.282	U-0.052	U-0.052	-	U-0.033	U-0.033	U-0.033	U-0.033	U-0.033	U-0.033	U-0.033	U-0.033	U-0.033	U-0.033	U-0.033	U-0.033
<b>Slab-on-Grade Floors</b>																	
Unheated slabs	F-0.730	F-0.730	F-0.730	F-0.730	F-0.730	F-0.730	F-0.730	F-0.540	F-0.730	F-0.540	F-0.540	F-0.520	F-0.520	F-0.520	F-0.520	F-0.510	
Heated slabs	F-1.020	F-1.020	F-1.020	F-1.020	F-0.900	F-0.900	-	F-0.860	F-0.860	F-0.860	F-0.860	F-0.688	F-0.830	F-0.688	F-0.688	F-0.688	

a. When heated slabs are placed below-grade, below grade walls must meet the F-factor requirements for perimeter insulation according to the heated slab-on-grade construction.